

Producer statement – PS3

Heating unit insert for timber cavities

Building consent number			
Site address			
Owner(s)		Telephone	
Agent/ contact		Telephone	
Unit make and model			
Unit serial number			
Please identify all appropriate pre-installation checks undertaken: (tick applicable)			
<input type="checkbox"/> Applicable <input type="checkbox"/> Not applicable	I have checked the timber structure complies with the consented documents and the manufacturers literature for the model of insert heating unit being installed.		
Please identify all appropriate installation criteria were undertaken: (tick applicable)			
<input type="checkbox"/> Applicable <input type="checkbox"/> Not applicable	The heating appliance was fitted with appropriate seismic restraints in accordance with the manufacturer’s literature and the issued consent.		
<input type="checkbox"/> Applicable <input type="checkbox"/> Not applicable	The manufacturer’s installation instructions have been followed in terms of fitting the heat proof insulating blanket surrounding the unit’s casing, any additional heat shielding necessary and venting of the timber cavity the heating unit has been installed within.		
<input type="checkbox"/> Applicable <input type="checkbox"/> Not applicable	The stainless-steel flue joint to the heating appliance spigot has been secured against separation with stainless steel rivets/ screws and appropriate heat proof sealant.		
<input type="checkbox"/> Applicable <input type="checkbox"/> Not applicable	Stainless-steel flue joints have been secured against separation with stainless steel rivets/ screws and appropriate heat proof sealant.		
<input type="checkbox"/> Applicable <input type="checkbox"/> Not applicable	The gap between the heating unit, the outer liner of the flue and the combustible materials exceeds the minimum required noted in the installation details of the heating unit specifications.		
<input type="checkbox"/> Applicable <input type="checkbox"/> Not applicable	The chimney cap has been separated from combustibles allowing the correct amount of air flow for cooling where the projection to the cowling is less than 600 millimetres.		
<input type="checkbox"/> Applicable <input type="checkbox"/> Not applicable	The chimney cap has been installed to lap cladding in accordance with table 7 of E2 AS1.		

CONTRACTOR DETAILS

Contractor’s full name	
Contractor’s registration or LBP number	
Address	

CONTRACTOR DETAILS

Telephone	
Email	
Please attach a photocopy or scanned image of the contractor's registration card.	

I _____ have sighted the issued building consent mentioned above and read the conditions. As the contractor I can confirm the building works described above were completed on _____ and have been undertaken in accordance with the consented plans/ specifications and the New Zealand Building Code.

By completing this form, I understand Southland District Council will rely upon this declaration for the purposes of establishing compliance with the building consent and satisfaction on reasonable grounds of compliance with the New Zealand Building Code.

Signature		Date	
-----------	--	------	--

The purpose of the PS3 Construction Statement is to provide Southland District Council with a permanent record of works carried out for the respective building consent.

- a) This form is not intended as a substitute for inspections but as supporting documentation for consideration by Southland District Council.
- b) If this document is to be used in the support of an inspection or to establish compliance with the consent, please make sure there has been written prior agreement noted on the inspection records or approved consent.

The acceptance or reliance on this document is at the sole discretion of Southland District Council.

Please contact Southland District Council building services team with any queries relation to this form by either email to building-cs@southlanddc.govt.nz or alternatively phone 0800 732 732.

FOR COUNCIL USE ONLY

Reason(s) for acceptance refusal

FOR COUNCIL USE ONLY			
Assessed by			
Signature		Date	